



DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-7301DQ0217

Registration Number
Registriernummer

Field of Application
Anwendungsbereich

products of water supply
Produkte der Wasserversorgung

Owner of Certificate
Zertifikatinhaber

Zhejiang Qilu Technology Co., Ltd.
BUILDING24, No.1399 LIANGMU ROAD, CN- Hangzhou

Distributor
Vertreiber

Zhejiang Qilu Technology Co., Ltd.
BUILDING24, No.1399 LIANGMU ROAD, CN- Hangzhou

Product Category
Produktart

Stainless tubes: Stainless steel tube (7301)

Product description
Produktbezeichnung

pipes made of stainless steel for the drinking water installation (1.4404)

Model
Modell

PiPress Stainless Steel Pipes

Test reports
Prüfberichte

Type testing: 242510-2 from 14.02.2025 (DTI)

Test basis
Prüfgrundlagen

DVGW GW 541 (01.10.2004)

Date of Expiry / File No. 14.02.2030 / 24-0322-WNE
Ablaufdatum / Aktenzeichen

70028-04-A-DE

08.05.2025 Gre A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

A. W. Z.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvwg-cert.com
www.dvbw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
PiPress Stainless Steel	Manufacturing group: 15 - 54	

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

Tested dimensions in accordance with EN 10312 - Series 2 (DVGW GW 541, Table 3):

15 x 1,0 mm; 18 x 1,0 mm, 22 x 1,2 mm, 28 x 1,2 mm, 35 x 1,5 mm, 42 x 1,5 mm, 54 x 1,5 mm

The hygiene suitability for drinking water is proven with "certificate of conformity hygiene" according to "Recommendation for attestation of conformity of product hygiene suitability for drinking water" of the German Federal Environment Agency (UBA):

UBA BWGL-Metalle: HyCert: Z-393206-24-Hy111





DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8511DQ0274

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Zhejiang Qilu Technology Co., Ltd. BUILDING24, No.1399 LIANGMU ROAD, CN- Hangzhou
Distributor <i>Vertreiber</i>	Zhejiang Qilu Technology Co., Ltd. BUILDING24, No.1399 LIANGMU ROAD, CN- Hangzhou
Product Category <i>Produktart</i>	Installation systems and system joints (PN 10): pipe joint for pipes in drinking water installation systems (8511)
Product description <i>Produktbezeichnung</i>	System connector: Pressfitting joint made of stainless steel, type M-MM, for stainless steel pipes in accordance with DVGW GW 541, unpressed leaky
Model <i>Modell</i>	PiPress Stainless Steel Fittings
Test reports <i>Prüfberichte</i>	Type testing: 242510-1, rev. 1 from 17.03.2025 (DTI)
Test basis <i>Prüfgrundlagen</i>	DVGW W 534-(P) (01.07.2015) DVGW CERT ZP 8500 (23.05.2022)

Date of Expiry / File No. 17.03.2030 / 24-0322-WNE
Ablaufdatum / Aktenzeichen

70028-04-A-DE

08.05.2025 Gre A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvwg-cert.com
www.dvbw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
PiPress Stainless Steel Fittings	Nominal diameter: 15 mm	
PiPress Stainless Steel Fittings	Nominal diameter: 18 mm	
PiPress Stainless Steel Fittings	Nominal diameter: 22 mm	
PiPress Stainless Steel Fittings	Nominal diameter: 28 mm	
PiPress Stainless Steel Fittings	Nominal diameter: 35 mm	
PiPress Stainless Steel Fittings	Nominal diameter: 42 mm	
PiPress Stainless Steel Fittings	Nominal diameter: 54 mm	

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

Pipes to use:

Stainless steel pipes in accordance with DVGW GW 541,
dimensions in accordance with EN 10312 - Series 2 (DVGW GW 541, Table 3)

The hygiene suitability for drinking water is proven with "certificate of conformity hygiene" according to "Recommendation for attestation of conformity of product hygiene suitability for drinking water" of the German Federal Environment Agency (UBA):

UBA BWGL-Metalle: HyCert: Z-393206-24-Hy111

